

ADDENDUM NUMBER 1

Request for Bid: Veterans Memorial Park Trails Improvements Project – Blue Trail Raised Boardwalk (November 2015)

Date this Addendum Issued: Monday, Nov. 9, 2015

From: Philip Hervey, Town Planner, Barrington, RI

283 County Road, Barrington, RI

(401) 247-1900 x347 (office)

phervey@barrington.ri.gov (e-mail)

This Addendum has been included in the Bid Documents

GENERAL INSTRUCTIONS:

- This Addendum constitutes an integral part of the above-referenced Request for Bid and shall be read in conjunction with the Request.
 - Where inconsistent with the original Request, or any subsequent Addendum, this Addendum shall govern.
 - It is the responsibility of all Proposers to conform to this Addendum.
 - Unless specifically changed herein, all other requirements of the Request shall remain in full force and effect and can only be modified if in writing.
-

PURPOSE OF THIS ADDENDUM: Clarify design specifications.

1. Add the following specification:

(site access and staging area – West end of Bosworth Street, Barrington, RI)

2. Revise Plan Sheet 2: Details as follows:

Reduce width of boardwalk from 6 feet to 5 feet (as Per Detail 4: Raised Boardwalk Cross Section)

3. Amend Section 02766: Wood Site Work, Page 2, 1.04-Submittals, D1, to read as follows:

The Contractor shall prepare and submit to the Owner, for review and approval, working drawings and design calculations for the Helical Piles intended for use at least four (4) calendar days prior to planned start of construction. All submittals shall be signed and sealed by a Registered Professional Engineer currently licensed in the State of Rhode Island.

END OF THIS ADDENDUM

11/9/15