

ADDENDUM NUMBER 2

Request for Bid: Veterans Memorial Park Trails Improvements Project – Blue Trail Raised Boardwalk (November 2015)

Date this Addendum Issued: Monday, Nov. 10, 2015

From: Philip Hervey, Town Planner, Barrington, RI

283 County Road, Barrington, RI

(401) 247-1900 x347 (office)

phervey@barrington.ri.gov (e-mail)

This Addendum has been included in the Bid Documents

GENERAL INSTRUCTIONS:

- This Addendum constitutes an integral part of the above-referenced Request for Bid and shall be read in conjunction with the Request.
 - Where inconsistent with the original Request, or any subsequent Addendum, this Addendum shall govern.
 - It is the responsibility of all Proposers to conform to this Addendum.
 - Unless specifically changed herein, all other requirements of the Request shall remain in full force and effect and can only be modified if in writing.
-

PURPOSE OF THIS ADDENDUM: To revise bid documents and provide a clarification, as follows:

1. Page 2 of **Instructions to Bidders** – third paragraph (under “Interpretation”): “Questions to be submitted five (5) working days before the date set for receipt of bids.”
 - Revise to “Questions to be submitted five (5) calendar days before the date set for receipt of bids.”
2. **Section 02270**, Part 1, subsection 1.02A.
 - Revise to add Straw Wattles to list of acceptable erosion control devices.
3. **Section 02766**, Part 1, subsection 1.02
 - Revise to eliminate items A, B, and D
4. **Section 02766**, Part 2, subsection 2.03 – The specifications specify “CHANCE Civil Construction, or approved equal.” The engineering drawing in the bidding documents specify “E.C.P.” on the helical anchor design.
 - Revise to “CHANCE Civil Construction, E.C.P., or any other approved equal.”
5. **Site Plan, Sheet 1**
 - Revise to note that new Blue Trail connections to be completed “by others”.
6. **Details, Sheet 2**
 - Revise New Blue Trail Connector Segment detail to specify to be completed “by others.”
7. **Clarification:** Addendum 1 revised the dimension of the boardwalk on Plan Sheet 2 such that the width of the boardwalk is reduced from 6 feet to 5 feet

END OF THIS ADDENDUM

11/10/15